



Ontario's One-Stop Painting & Coating Experts

CENTRAL PAINTING INC.
COMMERCIAL • INDUSTRIAL • ELECTRO-STATIC • BLASTING SERVICES



Allow us to provide you with the correct coating solution for your ceilings, walls & plant machinery.

1.888 456.0926
info@centralpainting.com



www.centralpainting.com



INDUSTRIAL FLOOR SYSTEMS

"We Repair, Protect and Refinish Concrete"

Let IFS provide you with a long lasting floor system.
Serving all of Ontario

We Specialize in Concrete Polishing and Floor Repairs

Other services include:

- Rapid curing MMA coatings (The One Hour Floor!)
- ESD Floors
- Epoxy & Urethane coatings



p. 1.888.726.7140
f. 1.888.726.7148
w. www.industrialfloorsystems.com
e. sales@industrialfloorsystems.com



emergency procedures and other duties outlined in the Fire Safety Plan must be given to all supervisory staff. Employees should receive training in the safe use of portable fire extinguishers and other fire safety equipment. This would include instructions on how to activate and reset the fire alarm system where appropriate. Staff must be instructed to react quickly to a fire emergency. At the same time, personal safety must be promoted.

The elected supervisory staff within an industrial occupancy is to be notified by employees in the event any part of the fire protection system(s) is shutdown temporarily, at which time the fire department must be notified by company personnel to this effect. In the event the temporarily shutdowns are in excess of 24 hours, written notification is forwarded to the fire department for their acceptance. The alternative measures are then implemented as outlined in the fire safety plan for the areas which are not being protected such as the fire watch procedures conducted on the hour, notification postings placed throughout the areas not protected and alerting all the employees within the building. It is a requirement that all employees are continually advised who the actual supervisory staff are for the purposes of reporting all fire equipment shutdowns, alerting them of any known fire hazards, safety risks or threats to life within their premise. The supervisory staff must be listed within the fire safety plan and continually kept current. In the event the fire protection system(s) are activated as a result of an emergency occurring in the premise, the supervisory staff is not permitted to reset or restore any part of fire protection system(s) unless authorization is given by the fire department.

Article provided by:

Mr. Fred Baumgartner, President,
Firepoint Technologies, Brampton,
Ontario Tel. 905. 874. 9400

Paul Donnelly is a regular contributing editor to OIM. If you'd like more information on this article, please contact pdonnelly@oim-online.com

